



GOVERNMENT OF KARNATAKA
DISTRICT HEALTH AND FAMILY WELFARE OFFICE
BIDAR DISTRICT, BIDAR-585401

Email ID: dhobidar@gmail.com

Phone: 08482-233126/7

Ref. No: DHFWOB/CR/2026-27

Date: 21/08/2026

**PROFORMA REGARDING SAFE DRINKING WATER AND
SANITARY CONDITION CERTIFICATE**

This is to certify that on the request of the Applicant Trust/Society, "HIREMATH SAMSTHAN VIDYAPEETH TRUST ® BHALKI", a joint physical verification for the ANUBHAVA MANTAP GURUKULA PUBLIC SCHOOL Tq. AURAD Dist.BIDAR.

It is certified that an inspection team headed by DR. DYANESHWAR NIRGUDE, DISTRICT HEALTH & FAMILY WELFARE OFFICER, BIDAR from DISTRICT HEALTH AND FAMILY WELFARE OFFICER, BIDAR inspected the ANUBHAVA MANTAP GURUKULA PUBLIC SCHOOL Tq. AURAD Dist.BIDAR on 05/06/2026 and found that the ANUBHAVA MANTAP GURUKULA PUBLIC SCHOOL Tq. AURAD Dist.BIDAR has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic condition of the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above is valid for a period of **One Year** from the issuing date.

Signature with Seal:

Name: DR. DYANESHWAR NIRGUDE
District Health and Family Welfare Officer,
Bidar District, Bidar



RURAL DRINKING WATER & SANITATION DEPARTMENT, Gok
SUB DIVISION LEVEL WATER QUALITY CHEMICAL TESTING LABORATORY AURAD(B),
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
RDW&SD SUB DIVISION AURAD(B)-585326, BIDAR, KARNATAKA, INDIA
Email ID:rdwsd.wqmssp.auradlab@gmail

TEST REPORTS

TO,
PRINCIPAL
ANUBHAVA MANTAP GURUKUL PUBLIC SCHOOL SANTHPUR
TALUKA : AURAD(B)
DIST : BIDAR
ADDRESS OF THE SAMPLE LOCATION : WPP IN ANUBHAVA
MANTAP GURUKUL PUBLIC SCHOOL SANTHPUR

Report date:18.08.2026
 Report Number:26PVT007
 Reference: Sample receipt Form (Departmental).
 Sample receipt date:17.08.2026
 Sample code: **AUR26PVT007**
 Date of Sample collection: 17.08.2026
 Analysis start date:17.08.2026
 Analysis completion date:18.08.2026
 Sample collection protocol: APHA 24th Edition
 Environmental Condition: Temp°C: 25.2°C
 Sample quantity: 1 Liter

Sample Particulars: **WPP**

Sl.No	Test	Results	Acceptable Limit IS 10500: 2012 RA:2018	Permissible Limit IS 10500: 2012 RA:2018	Protocol
Sample Description / Condition:Clear					
1.	pH Value @25°C	8.34	6.5 – 8.5	No relaxation	IS 3025 (Part 11): 2022
2.	Specific Conductancems/cm@ 25°C Temp°C	218	—	—	IS 3025 (Part 14): 2013 RA:2023
3.	Odor	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4.	Color, Hazen Units	5	5	15	IS 3025 (Part-4) :2021 a) Platinum Cobalt (Visual Comparison) Method.
5.	Turbidity, NTU	0.3	1	5	IS 3025 (Part 10): 1984 RA:2023
6.	Total Dissolved Solids@ 180°C, mg/l	106	500	2000	IS 3025 (Part 16): 1984 -Filterable Residue (Total Dissolved Solids) at 180°C
7.	Alkalinity as CaCO ₃ , mg/l	28.14	200	600	IS 3025 (Part 23) :2023
8.	Total Hardness as CaCO ₃ , mg/l	48.04	200	600	IS 3025(Part 21): 2009 a) EDTA Method for Determination of Hardness.
9.	Calcium as Ca, mg/l	12.82	75	200	IS 3025 (Part 40): 2024 a) EDTA Titrimetric Method.
10.	Magnesium as Mg, mg/l	3.89	30	100	IS 3025(Part 46): 2023 a) Volumetric method using EDTA
11.	Chloride as Cl, mg/l	15.00	250	1000	IS 3025 (Part-32): 1998 a) Argentometric Method
12.	Sulphate as SO ₄ , mg/l	7.25	200	400	IS 3025 (Part 24/Sec1): 2022 b) Turbidity Method
13.	Fluoride as F, mg/l	0.02	1	1.5	APHA 24 rd Edition 4500-F: D R
14.	Nitrate as NO ₃ , mg/l	8.60	45	No relaxation	APHA 24 rd Edition 4500-NO3-B
15.	Iron as Fe, mg/l	0.08	1	No relaxation	IS 3025 (Part 53): 2003 a) 1,10 phenanthroline method.

Remarks: The Given Sample Conforms to the Acceptable limit of IS 10500: 2012 RA: 2018 ,Drinking Water Specifications for Above tested Physical and Chemical Parameters .

Analyzed by: *Ashwaroshan*
 Analyst
 Ashwaroshan
 18/08/2026

Authorized Signatory
 ASSISTANT EXECUTIVE ENGINEER (MARUTHI RATHOD)
 Date:18.08.2026

Note:

- The above results relate only to the sample tested.
- The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- Samples will be discarded after 15 days from the date of report generation.
- Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01.
- Note: BDL- Below Detection Limit. NTU: Nephelometric meter
- Sample collected and submitted by the CLIENT.

RDWSD/ WQMSP/ T&R/01

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
 ಗ್ರಾ. ಕು. ನೀ. & ಸೈ. ಉಪ-ವಿಭಾಗ
 ಬಿರಾದ (ಬಾ)